

#### PUSH-BUTTONS ASSIGNMENT

Button	Command
1	R1 + R5
2	R2 + R5
3	R3 + R5
4	R4 + R5
5	-
6	-
7	-
8	-


The Pocket control unit is powered automatically when a button is pushed

The Pocket turns off:  
 - automatically after 10 s is not used.  
 - automatically after 30s when it doesn't communicate with the Receiver

Each push-button commands relay R5 together with relays from R1 to R4.

The R5 relay turns off with a 0.5 s delay.

#### INTERNAL CONNECTIONS:



Supply voltage: 10 -28V

Max current specifications:  
 - each relay 10A